

Tertiaire sans clim

envirobat Réunion avril 2011

Les bureaux de

l'ilet du centre

à Saint Pierre



données

Maître d'ouvrage

Jean Michel et Marie Claude Luspot

Architectes

2apmr + APA

LEU Réunion *environnement*

Position : centre ville de Saint pierre

altitude 75 m ngr moyen

Commune de Saint-Pierre (centre-ville)

Année d'achèvement: 2008

66 logements (du T1 au T4)

312 m² de bureaux

SHON 4123 m²

COS: 1

Occupation des bureaux

depuis Février 2008

Occupation des logements

Depuis janvier 2008 et janvier 2009

Photographie Hervé Douris





PLAN DE SITUATION







Rue Joseph Hubert

Rue François Isautier

Limite des propriétés

Cloture existante

3.00

4.00

4.00

PLAN DE MASSE

0 5 10 15

Conception bioclimatique

L'îlot urbain







Surfaces vertes

-  Espaces verts
1480 m²
-  Dalle herbe
260 m²
-  Toiture végétalisée
60 m²




Surfaces grises

1745.45 m²


99 places de stationnement

17.6m²/voiture



Emprise au sol

1615 m²
40%







Conception bioclimatique

Les bureaux








Plan d'aménagement du RDC et double peaux

Au **nord** la pergola urbaine desservant les logements

Au **sud** les paves soleil et la coursive pour les incidences solaires d'été en soirée





Bureaux: diminution des charges internes (informatique)



Postes de travail: écran + clavier + souris




Unités centrales: regroupées dans local informatique sécurisé et climatisé

simulations numériques du confort thermique

CFD sur les écoulements d'air en ventilation naturelle

Une étude de thèse en mécanique des fluides par Xavier Gillard






Figure 3: Results for the night thermal breezes simulation on cross sections

3.2 Thermal Simulation over a Complete Year

Once calibrated, the numerical model was used to perform a simulation over an entire year. The results — mean operative temperature and relative humidity in the offices during working hours — were then plotted on a psychrometric diagram. Three zones were defined to assess thermal comfort: one corresponds to still air, the second corresponds to airflow of 0.5m/s (corresponding to strong trad winds, see above), the last one, corresponds to airflows of 1 m/s, which can only be achieved by the use of ceiling fans.

The conclusion is that thermal comfort can be achieved with natural ventilation airflows between May and October; in March, April and November, the use of ceiling fans is often required; from December to February, it is mandatory almost all the time.

3.3 The Drawback Effect of Natural Ventilation

Five scenarios were then defined and modelled, in order to understand the building's behavior in more details: natural night cooling, mechanical night cooling, closed offices (with and without night cooling), absence of shading devices.

The first conclusion drawn from these analyses is that, despite the high air change rates involved by natural ventilation, the operative temperature is maintained below the external air temperature almost all the year long. The importance of this conclusion does not lie in the fact that difference of temperature is positive (it is indeed on the order of 0.2° C), but rather in the fact that it is not negative. The fact that natural ventilation can hardly lead to air temperatures lower than the external one constitutes already a high disadvantage, if the radiant temperature tended to rise the effective temperature, the results would be even worse.

3.4 Note on Night Cooling

The second conclusion, more important, is that night cooling, not yet implemented but considered as an option for improving the existing, thermal conditions would result in a low impact on the operative temperature during the working hours.

First, the CFD and thermal simulations, as well as measurements, proved that night ventilation would not be homogeneous in the whole offices.

Assuming an efficient night ventilation, and closing the offices openings does not help 4. The heat exchanges by ventilation, or through the non insulated walls, glazing elements and floor, would rise the air temperature to a point such that the effect of the diminution of the radiant temperature are negligible.




Figure 4: Comparison of the base case average operative temperature to that of the fourth scenario (closed offices during the day, efficient ventilation a night), for the moderate period.

4 Conclusion

The dynamic thermal simulations presented above are expected to be of good quality. Extensive access to the building's characteristics was allowed, sensitivity analyses were performed for the uncertain assumptions and a comparison to measurements was carried out.

CFD simulations, on the other hand, should be considered with more caution. For resource limitation considerations, the model was indeed drastically simplified, and only three scenarios were investigated. However, they are assumed to provide an acceptable description of the internal airflows, as well as a good indication on the highest achievable velocity magnitude.

Put together, the results of these two types of simulations, together with a measurement campaign allowed to draw different conclusions on the building's behavior:

- thermal comfort within the offices is achievable all the year long, either by natural ventilation (from May to October), or with the help of the ceiling fans;
- a night cooling strategy, either natural or mechanical, would have little effect on the daytime thermal comfort.

References

- [1] Projet PERENE - PERformances ENERgétiques des bâtiments à la Réunion - rapport final. Technical report, INSET, 2004.




Figure 4: Comparison of the base case average operative temperature to that of the fourth scenario (closed offices during the day, efficient ventilation a night), for the moderate period.




Figure 2: Comparison of humidity results to measurements for the thermal model calibration.

Retours d'expérience


*Occupation des bureaux
depuis Février 2008*



ETUDE DU CONFORT THERMIQUE

Période: Eté austral, du 25 Février au 25 Mars 2011

Enregistreurs de donnée de température et d'humidité relative




RESULTATS:


Etude globale (1 mois) en période d'été

Pendant les horaires de bureau, de 8h00 à 18h00

- Température moyenne dans la rue 32,86°C
- Température moyenne dans les bureaux 29,29°C



Evolution spatiale de la température dans l'Ilet du Centre








Bureaux: consommation énergétique

Surface totale: 310 m² utiles

Parc informatique: 20 ordinateurs personnels, 1 serveur, 2 onduleurs centralisés

Consommation électrique totale: **63 kWh/m²/an** (tous usages, mesures entre le 1^{er} mars 09 et 1^{er} mars 10)

Répartition des consommations:



Consommation électrique hors informatique-repro-cuisine: **15 kWh/m²/an**

Bureaux: consommation énergétique

	Bâtiment bureaux standard (Réunion)	PERENE 2009	Ilet du Centre
kWh/m2/an*	135	93	15
Surface climatisée	70 %	70 %	3 %

- Consommation électrique en énergie finale hors process ; surfaces utiles
- **Les 3% de clim sont utilisés pour le process et non les confort des usagers**

Optimisations possibles:

- Améliorer l'éclairage naturel
- Serveur informatique central
- Comptabilité énergétique



Merci de votre attention